

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD

Sys Fac ID: 17-05702

Last Inspected On: 7/21/2014

Operating Permit Renewal Date: 8/19/2017

Contact: Robert Wilson, (406) 557-2215

Owners/Operators: Farmers Union Oil Co Jordan, Owner

(406)-557-2215

PO BOX 449

JORDAN MT 59337-0449

Robert K Wilson, UST Class A Operator

Robert K Wilson, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
941			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000		1/16/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	
7	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
942			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
4,100		1/17/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	
8	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
943			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Continuous Interstitial Monitor	
4,100					
9	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
944			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
3,760		1/19/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD

Sys Fac ID: 17-05702
Last Inspected On: 7/21/2014
Operating Permit Renewal Date: 8/19/2017

Contact: Robert Wilson, (406) 557-2215

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
945			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Continuous Interstitial Monitor	
7,900					
11	17	12/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
946			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/30/2008	Manual Interstitial Monitor	Automatic Tank Gauging 0.2	
4,100		1/17/2015	TS-550 EVO , Incon	Continuous Interstitial Monitor	

Facility Summary in GARFIELD County in the City of JORDAN

Location: FELLMANS HARDWARE INC
MT HIGHWAY 200
JORDAN, MT 59337 GARFIELD
Contact: Richard Galla, (406) 557-2392

Sys Fac ID: 17-10707
Last Inspected On: 10/17/2013
Operating Permit Renewal Date: 11/7/2016

Owners/Operators: Fellmans Hardware Inc, Owner (406)-557-2206 C CORP
PO BOX 344
JORDAN MT 59337-0344
Kenneth Ellington, UST Class A Operator
Kenneth Ellington, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4311		10/17/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
8,000					
6	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4312		10/17/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000			TLS-350/Gilbarco EMC , Veeder Root		
7	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4313		10/17/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
4,000					

Facility Summary in GARFIELD County in the City of JORDAN

Location: FARMERS UNION OIL CO JORDAN 2
BRUSETT RD WEST
JORDAN, MT 59337 GARFIELD

Sys Fac ID: 60-15243

Last Inspected On: 5/21/2015

Operating Permit Renewal Date: 6/1/2018

Contact: Robert Wilson, (406) 557-2215

Owners/Operators: Farmers Union Oil Co Jordan, Owner

(406)-557-2215

PO BOX 449

JORDAN MT 59337-0449

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	01	10/28/2014	Aboveground Tank	Flexible Plastic	
5498	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	
2	01	10/28/2014	Aboveground Tank	Flexible Plastic	
5499	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	
3	01	10/28/2014	Aboveground Tank	Flexible Plastic	
5500	Yes	10/28/2014	None	Double-Walled	No
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, ELLD Line Tightness Testing	
15,000		10/28/2014	TS-550 EVO , Incon	Not Listed	